



NEW MEXICO
ENVIRONMENT DEPARTMENT
Ground Water Quality Bureau
1190 Saint Francis Drive / PO Box 5469
Santa Fe, NM 87502-5469
Phone (505) 827-2900 Fax (505) 827-2965
www.env.nm.gov



Draft: February 1, 2021

GROUND WATER QUALITY BUREAU
DISCHARGE PERMIT
Issued under 20.6.2 NMAC

Facility Name: Mora Wastewater Treatment Facility
Discharge Permit Number: DP-640
Facility Location: Off State Route 518, approximately 1.5 miles east of the intersection of State Routes 94 and 518
Mora, NM

County: Mora

Permittee: Mora MDWC & MSWA
Mailing Address: Elauterio Trujillo, Board President
P.O. Box 304
Mora, NM 87732

Facility Contact: Clarence Aragon, Operations Manager
Telephone Number/Email: (575) 387-2767/mwsa@nnmt.net

Permitting Action: Renewal

Permit Issuance Date: DATE
Permit Expiration Date: DATE

NMED Permit Contact: Avery Young
Telephone Number/Email: (505) 699-8564/avery.young@state.nm.us

MICHELLE HUNTER
Chief, Ground Water Quality Bureau

TABLE OF CONTENTS

I.	INTRODUCTION	1
II.	FINDINGS.....	2
III.	AUTHORIZATION TO DISCHARGE	3
IV.	CONDITIONS	3
	A. OPERATIONAL PLAN	3
	Operational Actions with Implementation Deadlines.....	4
	Operating Conditions.....	5
	B. MONITORING AND REPORTING	7
	Due Dates for Monitoring Reports	7
	Monitoring Actions with Implementation Deadlines.....	7
	Groundwater Monitoring Conditions.....	8
	Facility Monitoring Conditions	9
	C. CONTINGENCY PLAN	11
	D. CLOSURE PLAN	15
	E. GENERAL TERMS AND CONDITIONS	16
ATTACHMENTS		
	Discharge Permit Summary	

I. INTRODUCTION

The New Mexico Environment Department (NMED) issues this groundwater discharge permit Renewal (Discharge Permit or DP-640) to the Mora Mutual Domestic Water Consumers and Mutual Sewage Works Association (MMDWCA & MSWA or Permittee) pursuant to the New Mexico Water Quality Act (WQA), NMSA 1978 §§74-6-1 through 74-6-17, and the New Mexico Water Quality Control Commission (WQCC) Ground and Surface Water Protection Regulations, 20.6.2 NMAC.

NMED's purpose in issuing this Discharge Permit, and in imposing the requirements and conditions specified herein, is to control the discharge of water contaminants from the Mora Wastewater Treatment Facility (Facility) in order to protect groundwater and those segments of surface water gaining from groundwater inflow for present and potential future use as domestic and agricultural water supply and other uses, and to protect public health. It is NMED's determination in issuing this Discharge Permit that the Permittee has met the requirements of Subsection C of 20.6.2.3109 NMAC. The Permittee is responsible for complying with the terms and conditions of this Discharge Permit pursuant to Section 20.6.2.3104 NMAC; failure to do so may result in enforcement action by NMED (20.6.2.1220 NMAC).

Described below are the activities that produce the discharge, the location of the discharge, and the quantity, quality and flow characteristics.

A package plant receives and treats domestic wastewater at a volume of up to 60,000 gallons per day (gpd). The Permittee discharges treated wastewater to the Mora River under National Pollutant Discharge Elimination System (NPDES) permit number NM0024996. The wastewater system also utilizes two synthetically lined impoundments. The North Impoundment provides for high flow diversion and flow stabilization storage and the South Impoundment provides storage prior to eventual disposal of aerobically digested sludge.

The discharge may contain water contaminants or toxic pollutants elevated above the standards of Section 20.6.2.3103 NMAC and is not subject to the exemption at Subsection 20.6.2.3105.A NMAC.

The Facility is located off State Route 518, approximately 1.5 miles east of the intersection of State Routes 94 and 518 in Mora, in Section 12, Township 20N, Range 15E, Mora County. A discharge at the Facility is most likely to affect groundwater at a depth of approximately 14 feet and having a total dissolved solids (TDS) concentration of approximately 325 milligrams per liter.

NMED issued the original Discharge Permit to the Permittee on March 8, 1990 and subsequently renewed and/or modified the Permit on February 17, 1995, May 3, 2001, and January 15, 2015. The application (i.e., discharge plan) associated with this Discharge Permit consists of the

materials submitted by the Permittee dated June 2, 2020, and materials contained in the administrative record prior to issuance of this Discharge Permit. The Permittee shall manage the discharge in accordance with all conditions and requirements of this Discharge Permit.

NMED reserves the right to require a Discharge Permit modification in the event NMED determines that the Permittee is or may be violating, or is likely to violate in the future, the requirements of 20.6.2 NMAC or the standards of Section 20.6.2.3103 NMAC. NMED reserves this right pursuant to Section 20.6.2.3109 NMAC. An NMED requirement to modify the Discharge Permit may result from a determination by NMED that structural controls and/or management practices approved under this Discharge Permit are insufficiently protective of groundwater quality and human health. NMED reserves the right to require the Permittee implement abatement of water pollution and remediate groundwater quality.

NMED's issuance of this Discharge Permit does not relieve the Permittee of the responsibility to comply with the WQA, WQCC Regulations, and any other applicable federal, state and/or local laws and regulations, such as zoning requirements and nuisance ordinances.

This Discharge Permit may use the following acronyms and abbreviations.

Abbreviation	Explanation	Abbreviation	Explanation
BOD ₅	biochemical oxygen demand (5-day)	NMSA	New Mexico Statutes Annotated
CFR	Code of Federal Regulations	NO ₃ -N	nitrate-nitrogen
CFU	colony forming unit	NTU	nephelometric turbidity units
Cl	chloride	QA/QC	Quality Assurance/Quality Control
EPA	United States Environmental Protection Agency	TDS	total dissolved solids
gpd	gallons per day	TKN	total Kjeldahl nitrogen
LAA	land application area	total nitrogen	= TKN + NO ₃ -N
LADS	Land Application Data Sheet(s)	TRC	total residual chlorine
mg/L	milligrams per liter	TSS	total suspended solids
mL	milliliters	WQA	New Mexico Water Quality Act
MPN	most probable number	WQCC	Water Quality Control Commission
NMAC	New Mexico Administrative Code	WWTF	Wastewater Treatment Facility
NMED	New Mexico Environment Department		

II. FINDINGS

In issuing this Discharge Permit, NMED finds the following.

1. The Permittee is discharging effluent or leachate from the Facility so that such effluent or leachate may move into groundwater of the State of New Mexico that has an existing concentration of 10,000 mg/L or less of TDS, within the meaning of Subsection A of 20.6.2.3101 NMAC, without exceeding standards of 20.6.2.3103 NMAC for any water contaminant.
2. This Discharge Permit allows the Permittee to discharge effluent or leachate from the Facility directly or indirectly into groundwater pursuant to this Discharge Permit and Sections 20.6.2.3000 through 20.6.2.3114 NMAC.
3. The discharge from the Facility is not subject to any of the exemptions of Section 20.6.2.3105 NMAC.

III. AUTHORIZATION TO DISCHARGE

The Permittee is responsible for ensuring that discharges authorized by this Discharge Permit are consistent with the terms and conditions herein pursuant to 20.6.2.3104 NMAC.

This Discharge Permit authorizes the Permittee to receive and treat up to 60,000 gpd of domestic wastewater using a package plant. The Permittee is authorized to discharge treated wastewater to the Mora River under National Pollutant Discharge Elimination System (NPDES) permit number NM0024996. This Discharge Permit also authorizes the Permittee to utilize two synthetically lined impoundments as part of the wastewater system.

[20.6.2.3104 NMAC, Subsection C of 20.6.2.3106 NMAC, Subsection D of 20.6.2.3109 NMAC]

IV. CONDITIONS

NMED issues this Discharge Permit for the discharge of water contaminants subject to the following conditions.

A. OPERATIONAL PLAN

#	Terms and Conditions
1.	The Permittee shall implement the following operational plan to ensure compliance with Title 20, Chapter 6, Parts 2 and 4 NMAC. [Subsection C of 20.6.2.3109 NMAC]

#	Terms and Conditions
2.	<p>The Permittee shall operate in a manner that does not violate standards and requirements of Sections 20.6.2.3101 and 20.6.2.3103 NMAC.</p> <p>[20.6.2.3101 NMAC, 20.6.2.3103 NMAC, Subsection C of 20.6.2.3109 NMAC]</p>

Operational Actions with Implementation Deadlines

#	Terms and Conditions
3.	<p>Within 30 days of the issuance date of this Discharge Permit (by DATE), the Permittee shall post signs indicating that the wastewater at the Facility is not potable. The Permittee shall post signs at the Facility entrance and other areas where there is potential for public contact with wastewater. Posted signs shall be in English and Spanish and shall be legible during the term of this Discharge Permit.</p> <p>The Permittee shall submit documentation demonstrating sign installation that consists of date stamped photographs to NMED in the next required periodic monitoring report.</p> <p>[Subsections B and C of 20.6.2.3109 NMAC, NMSA 1978, § 74-6-5.D]</p>
4.	<p>Within 60 days following the issuance date of this Discharge Permit (by DATE), the Permittee shall measure the thickness of the settled solids in the North and South Impoundments. The Permittee shall report the results of the solids thickness measurements to NMED in the next required periodic monitoring report.</p> <p>The Permittee shall measure the thickness of settled solids in accordance with the following procedure.</p> <ul style="list-style-type: none">a) The division of the total surface area of the treatment impoundment into nine equal sub-areas.b) One measurement (to the nearest half foot) using a settled solids measurement device (e.g., core sampler) per sub-area.c) Calculation of the average of the nine measurements. <p>In the event that the measured settled solids exceed one-third of the maximum liquid depth in the impoundment, the Permittee shall implement the Contingency Plan set forth in this Discharge Permit.</p> <p>[Subsection A of 20.6.2.3107 NMAC, Subsection C of 20.6.2.3109 NMAC]</p>

Operating Conditions

#	Terms and Conditions
5.	<p>The Permittee shall maintain fences around the Facility to restrict access by the general public and animals. The fences shall consist of a minimum of six-foot chain link or field fencing and locking gates. The Permittee shall maintain the fences to serve the stated purpose throughout the term of this Discharge Permit.</p> <p>[Subsections B and C of 20.6.2.3109 NMAC, NMSA 1978, § 74-6-5.D]</p>
6.	<p>The Permittee shall maintain the impoundment liners to avoid conditions that could affect the liner or the structural integrity of the impoundments. Characterization of such conditions may include the following:</p> <ul style="list-style-type: none">• erosion damage;• animal burrows or other damage;• the presence of vegetation including aquatic plants, weeds, woody shrubs or trees growing within five feet of the top inside edge of a sub-grade impoundment, within five feet of the toe of the outside berm of an above-grade impoundment, or within the impoundment itself;• the presence of large debris or large quantities of debris in the impoundment;• evidence of seepage; or• evidence of berm subsidence. <p>The Permittee shall routinely control vegetation growing around the impoundments by mechanical removal that is protective of the impoundment liner.</p> <p>The Permittee shall visually inspect the impoundments and surrounding berms on a monthly basis to ensure proper maintenance. In the event that inspection reveals any evidence of damage that threatens the structural integrity of an impoundment berm or liner, or that may result in an unauthorized discharge, the Permittee shall implement the Contingency Plan set forth in this Discharge Permit.</p> <p>The Permittee shall create and maintain a log of all impoundment inspections which describes the date of the inspection, any findings and repairs and the name of the person responsible for the inspection. The Permittee shall make the log available to NMED upon request.</p> <p>[Subsection A of 20.6.2.3107 NMAC, Subsection C of 20.6.2.3109 NMAC]</p>
7.	<p>The Permittee shall preserve a minimum of two feet of freeboard, i.e., the liquid level in the impoundments and the elevation of the lowest-most top of the impoundment liner.</p>

#	Terms and Conditions
	<p>In the event that the Permittee determines that it cannot preserve two feet of freeboard in the impoundment, the Permittee shall implement the Contingency Plan set forth in this Discharge Permit.</p> <p>[Subsection A of 20.6.2.3107 NMAC, Subsection C of 20.6.2.3109 NMAC]</p>
8.	<p>The Permittee shall properly manage all solids generated by the treatment system to maintain effective operation of the system by removing solids as necessary and in accordance with associated equipment manufacturer's specifications. The Permittee shall contain, transport and dispose of all solids removed from the treatment process in accordance with all local, state, and federal regulations.</p> <p>The Permittee shall maintain manifests for all solids transported from the treatment Facility for off-site disposal. The manifests shall identify the name of the hauler, the date of off-site shipment, the volume of solids removed, the disposal method, and disposal location.</p> <p>[Subsection A of 20.6.2.3107 NMAC, Subsection C of 20.6.2.3109 NMAC]</p>
9.	<p>The Permittee shall inspect and clean the lift station as needed to prevent pump failure.</p> <p>The Permittee shall maintain a record of lift station inspections, repairs and cleanings. The Permittee shall make the record available to NMED upon request.</p> <p>[Subsection A of 20.6.2.3107 NMAC, Subsection C of 20.6.2.3109 NMAC]</p>
10.	<p>The Permittee shall utilize operators, certified by the State of New Mexico at the appropriate level pursuant to 20.7.4 NMAC, to operate the wastewater collection, treatment and disposal systems. A certified operator or a direct supervisee of a certified operator shall perform the operations and maintenance of all or any part of the wastewater system.</p> <p>The Permittee shall notify the NMED within 24 hours if at any time the Permittee no longer has a certified operator maintaining the system.</p> <p>[Subsection C of 20.6.2.3109 NMAC, 20.7.4 NMAC]</p>

B. MONITORING AND REPORTING

#	Terms and Conditions
11.	<p>The Permittee shall conduct the monitoring, reporting, and other requirements listed below in accordance with the monitoring requirements of this Discharge Permit.</p> <p>[Subsection A of 20.6.2.3107 NMAC, Subsection C of 20.6.2.3109 NMAC]</p>
12.	<p>METHODOLOGY – Unless otherwise specified by this Discharge Permit, or approved in writing by NMED, the Permittee shall use sampling and analytical techniques that conform with the references listed in Subsection B of 20.6.2.3107 NMAC.</p> <p>[Subsection B of 20.6.2.3107 NMAC]</p>
13.	<p>Quarterly monitoring - The Permittee shall perform monitoring and other Permit required actions during the following periods and shall submit quarterly reports to NMED by the following due dates:</p> <ul style="list-style-type: none">• January 1st through March 31st – due by May 1st;• April 1st through June 30th – due by August 1st;• July 1st through September 30th – due by November 1st; and• October 1st through December 31st – due by February 1st. <p>[Subsection A of 20.6.2.3107 NMAC]</p>

Monitoring Actions with Implementation Deadlines

#	Terms and Conditions
14.	<p>Within 180 days following the issuance date of this Discharge Permit (by DATE), the Permittee shall install the following flow meters.</p> <ol style="list-style-type: none">a) One totalizing flow meter installed on the influent line prior to the high flow diversion to measure the volume of wastewater received by the North Impoundment.b) One totalizing flow meter installed on the influent line to the South Impoundment to measure the volume of waste sludge discharged to the South Impoundment. <p>The Permittee shall submit confirmation of meter installation, type, calibration, and locations within 30 days of completed installations.</p> <p>[Subsection A of 20.6.2.3107 NMAC, Subsection C of 20.6.2.3109 NMAC]</p>

Groundwater Monitoring Conditions

#	Terms and Conditions
15.	<p>The Permittee shall perform quarterly groundwater sampling in the following groundwater monitoring wells and analyze the samples for TKN, NO₃-N, TDS and Cl.</p> <ul style="list-style-type: none">a) MW-1, located hydrologically upgradient of the Facility and 50 feet northwest of the northwest corner of the North Impoundment.b) MW-2, located hydrologically downgradient of the South Impoundment and 50 feet southeast of the southeast corner of the South Impoundment. <p>The Permittee shall properly collect, preserve, transport and analyze groundwater samples according to the following procedures.</p> <ul style="list-style-type: none">a) Measure the depth-to-most-shallow groundwater from the top of the well casing to the nearest hundredth of a foot.b) Purge three well volumes of water from the well prior to sample collection.c) Obtain samples from the well for analysis.d) Properly prepare, preserve and transport samples.e) Analyze samples in accordance with the methods authorized in this Discharge Permit. <p>The Permittee shall submit the depth-to-most-shallow groundwater measurements and laboratory analytical data results, including the QA/QC summary report and Chain of Custody, to NMED in the quarterly monitoring reports.</p> <p>[Subsection A of 20.6.2.3107 NMAC]</p>
16.	<p>NMED shall have the option to perform downhole inspections of all groundwater monitoring wells identified in this Discharge Permit. NMED shall establish the inspection date and provide at least a 60-day notice to the Permittee by certified mail. The Permittee shall remove any existing dedicated pumps at least 48 hours prior to NMED inspection to allow adequate settling time of sediment agitated from pump removal.</p> <p>Should the Permittee decide to install a pump monitoring well without a dedicated pump, the Permittee shall notify NMED at least 90 days prior to pump installation so that NMED can schedule a downhole well inspection(s) prior to pump placement.</p> <p>[Subsections A and D of 20.6.2.3107 NMAC]</p>

Facility Monitoring Conditions

#	Terms and Conditions
17.	<p>The Permittee shall measure the total monthly volume and calculate the daily average volume of wastewater received by the treatment facility each month using a primary measuring device (equipped with head sensing, totalizing and chart recording/data logging mechanisms) located at the headworks. The Permittee shall submit the totalized and average daily influent volumes for each month to NMED in the quarterly monitoring reports.</p> <p>[Subsection A of 20.6.2.3107 NMAC, Subsections C and H of 20.6.2.3109 NMAC]</p>
18.	<p>The Permittee shall on a monthly basis measure the volume of wastewater discharged to the North Impoundment during the period.</p> <p>To determine the discharge volume, the Permittee shall obtain readings from a totalizing flow meter located on the influent line prior to the high flow diversion on a monthly basis and calculate the monthly and average daily volume discharged to the impoundment. The Permittee shall submit monthly meter readings, calculated monthly discharge volumes and average daily discharge volumes to NMED in the quarterly monitoring reports.</p> <p>[Subsection A of 20.6.2.3107 NMAC, Subsections C and H of 20.6.2.3109 NMAC]</p>
19.	<p>The Permittee shall on a monthly basis measure the volume of sludge discharged to the South Impoundment during the period.</p> <p>To determine the discharge volume, the Permittee shall obtain readings from a totalizing flow meter located on the influent line to the South Impoundment on a monthly basis and calculate the monthly and average daily volume discharged to the impoundment. The Permittee shall submit monthly meter readings, calculated monthly discharge volumes and average daily discharge volumes to NMED in the quarterly monitoring reports.</p> <p>[Subsection A of 20.6.2.3107 NMAC, Subsections C and H of 20.6.2.3109 NMAC]</p>
20.	<p>All flow meters shall be capable of having their accuracy verified under working (i.e., real-time in-the-field) conditions. The Permittee shall develop a field verification method for each flow meter and shall utilize that method to check the accuracy of each respective meter. The Permittee shall perform field calibrations upon repair or replacement of a flow measurement device and, at a minimum, within 90 days of the issuance date of this Discharge Permit (by DATE), and then every other year thereafter.</p>

#	Terms and Conditions
	<p>The Permittee shall ensure each flow meter is calibrated to its manufacturer's recommended specification which shall be no less accurate than plus or minus 10 percent of actual flow, as measured under field conditions. An individual knowledgeable in flow measurement shall perform field calibration and the installation/operation of the device in use. The Permittee shall prepare a flow meter calibration report for each flow measurement device calibration event. The flow meter calibration report shall include the following information.</p> <ul style="list-style-type: none"> a) The location and meter identification. b) The method of flow meter field calibration employed. c) The measured accuracy of each flow meter prior to adjustment indicating the positive or negative offset as a percentage of actual flow as determined by an in-field calibration check. d) The measured accuracy of each flow meter following adjustment, if necessary, indicating the positive or negative offset as a percentage of actual flow of the meter. e) Any flow meter repairs made during the previous year or during field calibration. f) The name of the individual performing the calibration and the date of the calibration. <p>The Permittee shall maintain records of flow meter calibration(s) at a location accessible for review by NMED during Facility inspections.</p> <p>[Subsection A of 20.6.2.3107 NMAC, Subsections C and H of 20.6.2.3109 NMAC]</p>
21.	<p>The Permittee shall visually inspect flow meters on a monthly basis for evidence of malfunction. The Permittee shall maintain a log of the inspections that includes a date of the inspection, findings and repairs, and the name of the inspector. The Permittee shall make the log available to NMED upon request.</p> <p>If a visual inspection indicates a flow meter is not functioning as required by this Discharge Permit, the Permittee shall repair or replace the meter within 30 days of discovery. For <i>repaired</i> meters, the Permittee shall submit a report to NMED with the next monitoring report following the repair that includes a description of the malfunction; a statement verifying the repair; and a flow meter field calibration report completed in accordance with the requirements of this Discharge Permit. For <i>replacement</i> meters, the Permittee shall submit a report to NMED with the next monitoring report following the replacement that includes a design schematic for the device and a flow meter field calibration report completed in accordance with the requirements of this Discharge Permit.</p> <p>[Subsection A of 20.6.2.3107 NMAC, Subsection C of 20.6.2.3109 NMAC]</p>

#	Terms and Conditions
22.	<p>The Permittee shall submit records of solids disposal, including a copy of all Discharge Monitoring Reports (i.e., DMRs) required by the EPA pursuant to 40 CFR 503, for the previous calendar year, to NMED annually in the monitoring report due by August 1st each year.</p> <p>[Subsection A of 20.6.2.3107 NMAC]</p>

C. CONTINGENCY PLAN

#	Terms and Conditions
23.	<p>In the event that groundwater monitoring indicates that groundwater exceeds a standard identified in Section 20.6.2.3103 NMAC, the Permittee shall collect a confirmatory sample from the monitoring well within 15 days of receipt of the initial sampling results to confirm the initial sampling results.</p> <p>Within 60 days of confirmation of groundwater contamination, the Permittee shall submit to NMED a Corrective Action Plan (CAP) that proposes, at a minimum, contaminant source control measures and an implementation schedule. The Permittee shall the CAP as approved by NMED.</p> <p>Once this groundwater exceedance response condition is invoked whether during the term of this Discharge Permit or after the term of this Discharge Permit and prior to the completion of the Discharge Permit closure plan requirements, this condition shall apply until the Permittee has fulfilled the requirements of this condition and groundwater monitoring confirms for a minimum of eight (8) consecutive quarterly samples that groundwater does not exceed the standards of Section 20.6.2.3103 NMAC.</p> <p>Violation of the groundwater standard beyond 180 days after the confirmation of groundwater contamination may cause NMED to require the Permittee to abate water pollution consistent with the requirements and provisions of Section 20.6.2.4101, Section 20.6.2.4103, Subsections C and E of 20.6.2.4106, Section 20.6.2.4107, Section 20.6.2.4108 and Section 20.6.2.4112 NMAC.</p> <p>[Subsection A of 20.6.2.3107 NMAC, Subsection E of 20.6.2.3109 NMAC]</p>
24.	<p>In the event that information available to NMED indicates that a well is not constructed in a manner consistent with the attachment titled (Monitoring Well Guidance); contains insufficient water to effectively monitor groundwater quality; or is otherwise not completed in a manner that is protective of groundwater quality, the Permittee shall install a replacement well(s) within 120 days following notification from NMED.</p>

#	Terms and Conditions
	<p>The Permittee shall install replacement wells at locations approved by NMED prior to installation and shall complete replacement wells in accordance with the attachment Monitoring Well Guidance. The Permittee shall submit well construction and lithologic logs to NMED within 60 days following well completion.</p> <p>The Permittee shall properly plug and abandon a monitoring well requiring replacement upon completion of the replacement monitoring well. The Permittee shall complete the well plugging and abandonment, and shall document the abandonment procedures, in accordance with the attachment Monitoring Well Guidance and all applicable local, state, and federal regulations. The Permittee shall submit a copy of the well abandonment documentation to NMED within 60 days following the replacement well completion.</p> <p>[Subsection A of 20.6.2.3107 NMAC]</p>
25.	<p>In the event that an inspection reveals significant damage has occurred or is likely to affect the structural integrity of an impoundment or liner or their ability to contain contaminants, the Permittee shall propose the repair or replacement by submitting a Corrective Action Plan (CAP) to NMED for approval. The Permittee shall ensure the CAP is submitted to NMED within 30 days after discovery of the damage or following notification from NMED that significant damage is evident. The Permittee shall ensure the CAP includes a schedule for completion of corrective actions. The Permittee shall initiate implementation of the CAP following approval by NMED.</p> <p>[Subsection A of 20.6.2.3107 NMAC, Subsection C of 20.6.2.3109 NMAC]</p>
26.	<p>In the event that an impoundment cannot preserve a minimum of two feet of freeboard, the Permittee shall take actions to restore the required freeboard as authorized by this Discharge Permit and all applicable local, state, and federal regulations.</p> <p>In the event that two feet of freeboard cannot be restored within a period of 72 hours following discovery, the Permittee shall propose actions to restore two feet of freeboard by submitting a short-term Corrective Action Plan (CAP) to NMED for approval. Examples of short-term corrective actions include the pumping and hauling of excess wastewater from the impoundment or reducing the volume of wastewater discharged to the impoundment. The Permittee shall ensure the CAP includes a schedule for completion of corrective actions. The Permittee shall submit the CAP within 15 days following the date the Permittee or the NMED discover the exceedance. The Permittee shall implement the CAP following NMED approval.</p>

#	Terms and Conditions
	<p>In the event that the short-term corrective actions fail to restore two feet of freeboard, the Permittee shall submit to NMED a proposal for permanent corrective actions in a long-term CAP. The Permittee shall submit the long-term CAP within 90 days following failure of the short-term CAP. Examples corrective actions include the installation of an additional storage impoundment or a significant and permanent reduction in the volume of wastewater discharged to the impoundment. The Permittee shall ensure the long-term CAP includes a schedule for completion of corrective actions. The Permittee shall implement the CAP following NMED approval.</p> <p>[Subsection A of 20.6.2.3107 NMAC]</p>
27.	<p>In the event the average solids accumulation exceeds one-third of the maximum liquid depth in the impoundments, the Permittee shall propose a plan for the removal and disposal of the solids. The Permittee shall submit the solids removal and disposal plan to NMED for approval within 120 days following the issuance date of this Discharge Permit (by DATE) and includes the following information.</p> <ul style="list-style-type: none"> a) A method for removal of the solids to a depth of less than six inches throughout the treatment impoundment in a manner that is protective of the impoundment liner. b) A description of how the Permittee will contain, transport, and dispose of the solids in accordance with all local, state, and federal regulations, including 40 CFR Part 503. c) A schedule for completion of the solids removal and disposal project. <p>The Permittee shall initiate implementation of the plan following approval by NMED.</p> <p>[Subsection A of 20.6.2.3107 NMAC, Subsection C of 20.6.2.3109 NMAC]</p>
28.	<p>In the event that a release occurs that is not authorized under this Discharge Permit (commonly known as a “spill”), the Permittee shall take measures to mitigate damage from the unauthorized discharge and initiate the notifications and corrective actions required in Section 20.6.2.1203 NMAC and summarized below.</p> <p>Within <u>24 hours</u> following discovery of the unauthorized discharge, the Permittee shall verbally notify NMED and provide the following information.</p> <ul style="list-style-type: none"> a) The name, address, and telephone number of the person or persons in charge of the Facility, as well as of the owner and/or operator of the Facility. b) The name and address of the Facility. c) The date, time, location, and duration of the unauthorized discharge. d) The source and cause of unauthorized discharge. e) A description of the unauthorized discharge, including its estimated chemical composition. f) The estimated volume of the unauthorized discharge.

#	Terms and Conditions
	<p data-bbox="289 321 1419 352">g) Any actions taken to mitigate immediate damage from the unauthorized discharge.</p> <p data-bbox="289 401 1430 506">Within <u>one week</u> following discovery of the unauthorized discharge, the Permittee shall submit written notification to NMED providing the information listed above and any pertinent updates.</p> <p data-bbox="289 554 1430 701">Within <u>15 days</u> following discovery of the unauthorized discharge, the Permittee shall submit a Corrective Action Plan (CAP) to NMED describing any corrective actions previously taken and corrective actions to be taken relative to the unauthorized discharge. The CAP shall include the following information.</p> <ul data-bbox="289 709 1430 898" style="list-style-type: none">a) A description of proposed actions to mitigate damage from the unauthorized discharge.b) A description of proposed actions to prevent future unauthorized discharges of this nature.c) A schedule for completion of proposed actions. <p data-bbox="289 947 1430 1167">In the event that the unauthorized discharge causes or may with reasonable probability cause water pollution in excess of the standards and requirements of Section 20.6.2.4103 NMAC, and the water pollution will not be abated within 180 days after notice is required to be given pursuant to Paragraph (1) of Subsection A of 20.6.2.1203 NMAC, NMED may require the Permittee to abate water pollution pursuant to Sections 20.6.2.4000 through 20.6.2.4115 NMAC.</p> <p data-bbox="289 1215 1430 1289">The Permittee shall not construe anything in this condition as relieving them of the obligation to comply with all requirements of Section 20.6.2.1203 NMAC.</p> <p data-bbox="289 1337 553 1369">[20.6.2.1203 NMAC]</p>
29.	<p data-bbox="289 1392 1430 1581">In the event that NMED or the Permittee identifies any failures of the discharge plan, i.e., the application, or this Discharge Permit not specifically noted herein, NMED may require the Permittee to submit a Corrective Action Plan and a schedule for completion of corrective actions to address the failure(s). Additionally, NMED may require a discharge permit modification to achieve compliance with 20.6.2 NMAC.</p> <p data-bbox="289 1629 1227 1661">[Subsection A of 20.6.2.3107 NMAC, Subsection E of 20.6.2.3109 NMAC]</p>

D. CLOSURE PLAN

#	Terms and Conditions
30.	<p>The Permittee shall perform the following closure measures in the event the Facility, or a component of the Facility, the Permittee proposes to permanently close.</p> <p>Within <u>90 days</u> of ceasing to discharge to the treatment system, the Permittee shall complete the following closure measures.</p> <ul style="list-style-type: none">a) Plug the line leading to the system so that a discharge can no longer occur.b) Evaporate wastewater in the system components and storage impoundment, or drained and disposed of in accordance with all local, state, and federal regulations.c) Contain, transport, and dispose of solids removed from the treatment system in accordance with all local, state, and federal regulations, including 40 CFR Part 503. The Permittee shall maintain a record of all solids transported for off-site disposal. <p>Within <u>180 days</u> of ceasing to discharge to the treatment system (or unit), the Permittee shall complete the following closure measures.</p> <ul style="list-style-type: none">a) Remove all lines leading to and from the treatment system, or permanently plug and abandon them in place.b) Remove or demolish all treatment system components, and re-grade the area with suitable fill to blend with surface topography, promote positive drainage and prevent ponding.c) Perforate or remove the storage impoundment liners; fill the impoundments with suitable fill; and re-grade the impoundment sites to blend with surface topography, promote positive drainage and prevent ponding. <p>The Permittee shall continue groundwater monitoring until the Permittee meets the requirements of this condition and groundwater monitoring confirms for a minimum of eight consecutive quarterly groundwater sampling events that groundwater does not exceed the standards of Section 20.6.2.3103 NMAC . This period is referred to as “post-closure.”</p> <p>If at any time monitoring results show an exceedance of a groundwater quality standard in Section 20.6.2.3103 NMAC, the Permittee shall implement the Contingency Plan required by this Discharge Permit.</p> <p>Following notification from NMED that the Permittee may cease post-closure monitoring, the Permittee shall plug and abandon the monitoring well(s) in accordance with the attachment Monitoring Well Guidance.</p>

#	Terms and Conditions
	<p>When the Permittee has met all closure and post-closure requirements and verified appropriate actions with date stamped photographic evidence or an associated NMED inspection, the Permittee may submit to NMED a written request, including photographic evidence, for termination of the Discharge Permit.</p> <p>[Subsection A of 20.6.2.3107 NMAC, Subsection D of 20.6.2.4103 NMAC, 40 CFR Part 503]</p>

E. GENERAL TERMS AND CONDITIONS

#	Terms and Conditions
31.	<p>RECORD KEEPING - The Permittee shall maintain a written record of the following:</p> <ul style="list-style-type: none"> • Information and data used to complete the application for this Discharge Permit; • Information, data, and documents demonstrating completion of closure activities; • Any releases (commonly known as “spills”) not authorized under this Discharge Permit and reports submitted pursuant to 20.6.2.1203 NMAC; • The operation, maintenance, and repair of all facilities/equipment used to treat, store or dispose of wastewater; • Facility record drawings (plans and specifications) showing the actual construction of the Facility and bear the seal and signature of a licensed New Mexico professional engineer; • Copies of logs, inspection reports, and monitoring reports completed and/or submitted to NMED pursuant to this Discharge Permit; • The volume of wastewater or other wastes discharged pursuant to this Discharge Permit; • Groundwater quality and wastewater quality data collected pursuant to this Discharge Permit; • Copies of construction records (well log) for all sampled groundwater monitoring wells pursuant to this Discharge Permit; • The maintenance, repair, replacement or calibration of any monitoring equipment or flow measurement devices required by this Discharge Permit; and • Data and information related to field measurements, sampling, and analysis conducted pursuant to this Discharge Permit, including: <ul style="list-style-type: none"> ○ the dates, location and times of sampling or field measurements; ○ the name and job title of the individuals who performed each sample collection or field measurement; ○ the sample analysis date of each sample ○ the name and address of the laboratory, and the name of the signatory authority for the laboratory analysis;

#	Terms and Conditions
	<ul style="list-style-type: none"> ○ the analytical technique or method used to analyze each sample or collect each field measurement; ○ the results of each analysis or field measurement, including raw data; ○ the results of any split, spiked, duplicate or repeat sample; and ○ a copy of the laboratory analysis chain-of-custody as well as a description of the quality assurance and quality control procedures used. <p>The Permittee shall maintain the written record at a location accessible to NMED during a Facility inspection for a lifetime of the Discharge Permit. The Permittee shall make the record available to the department upon request.</p> <p>[Subsections A and D of 20.6.2.3107 NMAC]</p>
32.	<p>SUBMITTALS – The Permittee shall submit both a paper copy and an electronic copy of all notification and reporting documents required by this Discharge Permit, e.g., monitoring reports. The paper and electronic documents shall be submitted to the NMED Permit Contact identified on the Permit cover page.</p> <p>[Subsection A of 20.6.2.3107 NMAC]</p>
33.	<p>INSPECTION and ENTRY – The Permittee shall allow NMED to inspect the Facility and its operations that are subject to this Discharge Permit and the WQCC regulations. NMED may upon presentation of proper credentials, enter at reasonable times upon or through any premises in which a water contaminant source is located or in which any maintained records required by this Discharge Permit, the regulations of the federal government, or the WQCC are located.</p> <p>The Permittee shall allow NMED to have access to and reproduce for their use any copy of the records, and to perform assessments, sampling or monitoring during an inspection for the purpose of evaluating compliance with this Discharge Permit and the WQCC regulations.</p> <p>No person shall construe anything in this Discharge Permit as limiting in any way the inspection and entry authority of NMED under the WQA, the WQCC Regulations, or any other local, state or federal regulations.</p> <p>[Subsection D of 20.6.2.3107 NMAC, NMSA 1978, §§ 74-6-9.B and 74-6-9.E]</p>
34.	<p>DUTY to PROVIDE INFORMATION - The Permittee shall, upon NMED's request, allow for NMED's inspection/duplication of records required by this Discharge Permit and/or furnish to NMED copies of such records.</p>

#	Terms and Conditions
	[Subsection D of 20.6.2.3107 NMAC]
35.	<p>MODIFICATIONS and/or AMENDMENTS – In the event the Permittee proposes a change to the Facility or the Facility’s discharge that would result in a change in the volume discharged; the location of the discharge; or in the amount or character of water contaminants received, treated or discharged by the Facility, the Permittee shall notify NMED prior to implementing such changes. The Permittee shall obtain NMED’s approval (which may require modification of this Discharge Permit) prior to implementing such changes.</p> <p>[Subsection C of 20.6.2.3107 NMAC, Subsections E and G of 20.6.2.3109 NMAC]</p>
36.	<p>PLANS and SPECIFICATIONS – In the event the Permittee proposes to construct a wastewater system or change a process unit of an existing system such that the quantity or quality of the discharge will change substantially from that authorized by this Discharge Permit, the Permittee shall submit construction plans and specifications of the proposed system or process unit to NMED for approval prior to the commencement of construction.</p> <p>In the event the Permittee implements changes to the wastewater system authorized by this Discharge Permit that result in only a minor effect on the character of the discharge, the Permittee shall report such changes (including the submission of record drawings where applicable) to NMED prior to implementation.</p> <p>[Subsections A and C of 20.6.2.1202 NMAC, NMSA 1978, §§ 61-23-1 through 61-23-32]</p>
37.	<p>CIVIL PENALTIES - Any violation of the requirements and conditions of this Discharge Permit, including any failure to allow NMED staff to enter and inspect records or facilities, or any refusal or failure to provide NMED with records or information, may subject the Permittee to a civil enforcement action. Pursuant to WQA 74-6-10(A) and (B), such action may include a compliance order requiring compliance immediately or in a specified time, assessing a civil penalty, modifying or terminating the Discharge Permit, or any combination of the foregoing; or an action in district court seeking injunctive relief, civil penalties, or both. Pursuant to WQA 74-6-10(C) and 74-6-10.1, civil penalties of up to \$15,000 per day of noncompliance may be assessed for each violation of the WQA 74-6-5, the WQCC Regulations, or this Discharge Permit, and civil penalties of up to \$10,000 per day of noncompliance may be assessed for each violation of any other provision of the WQA, or any regulation, standard, or order adopted pursuant to such other provision. In any action to enforce this Discharge Permit, the Permittee waives any objection to the admissibility as evidence of any data generated pursuant to this Discharge Permit.</p>

#	Terms and Conditions
	[20.6.2.1220 NMAC, NMSA 1978, §§ 74-6-10 and 74-6-10.1]
38.	<p>CRIMINAL PENALTIES – No person shall:</p> <ul style="list-style-type: none"> • Make any false material statement, representation, certification or omission of material fact in an application, record, report, plan or other document filed, submitted or maintained under the WQA; • Falsify, tamper with or render inaccurate any monitoring device, method or record maintained under the WQA; or • Fail to monitor, sample or report as required by a permit issued pursuant to a state or federal law or regulation. <p>Any person who knowingly violates or knowingly causes or allows another person to violate the requirements of this condition is guilty of a fourth-degree felony and shall be sentenced in accordance with the provisions of NMSA 1978, § 31-18-15. Any person who is convicted of a second or subsequent violation of the requirements of this condition is guilty of a third-degree felony and shall be sentenced in accordance with the provisions of NMSA 1978, § 31-18-15. Any person who knowingly violates the requirements of this condition or knowingly causes another person to violate the requirements of this condition and thereby causes a substantial adverse environmental impact is guilty of a third-degree felony and shall be sentenced in accordance with the provisions of NMSA 1978, § 31-18-15. Any person who knowingly violates the requirements of this condition and knows at the time of the violation that he is creating a substantial danger of death or serious bodily injury to any other person is guilty of a second degree felony and shall be sentenced in accordance with the provisions of NMSA 1978, § 31-18-15.</p> <p>[20.6.2.1220 NMAC, NMSA 1978, §§ 74-6-10.2.A through 74-6-10.2.F]</p>
39.	<p>COMPLIANCE with OTHER LAWS - Nothing in this Discharge Permit shall be construed in any way as relieving the Permittee of the obligation to comply with any other applicable federal, state, and/or local laws, regulations, zoning requirements, nuisance ordinances, permits or orders.</p> <p>[NMSA 1978, § 74-6-5.L]</p>
40.	<p>RIGHT to APPEAL - The Permittee may file a petition for review before the WQCC on this Discharge Permit. Such petition shall be in writing to the WQCC within thirty days of the receipt of postal notice of this Discharge Permit and shall include a statement of the issues raised and the relief sought. Unless the Permittee files a timely petition for review, the decision of NMED shall be final and not subject to judicial review.</p> <p>[20.6.2.3112 NMAC, NMSA 1978, § 74-6-5.O]</p>

#	Terms and Conditions
41.	<p>TRANSFER of DISCHARGE PERMIT - Prior to the transfer of any ownership, control, or possession of this Facility or any portion thereof, the Permittee shall:</p> <ul style="list-style-type: none">• Notify the proposed transferee in writing of the existence of this Discharge Permit;• Include a copy of this Discharge Permit with the notice; and• Deliver or send by certified mail to NMED a copy of the notification and proof that the proposed transferee has received such notification. <p>The Permittee shall continue to be responsible for any discharge from the Facility, until both ownership and possession of the Facility have been transferred to the transferee.</p> <p>[20.6.2.3111 NMAC]</p>
42.	<p>PERMIT FEES – The Permittee shall be aware that the payment of permit fees is due at the time of Discharge Permit approval. The Permittee may pay the permit fees in a single payment or they may pay the fee in equal installments on a yearly basis over the term of the Discharge Permit. The Permittee shall remit single payments to NMED no later than 30 days after the Discharge Permit issuance date. The Permittee shall remit initial installment payments to NMED no later than 30 days after the Discharge Permit issuance date; with subsequent installment payments remitted to NMED no later than the anniversary of the Discharge Permit issuance date.</p> <p>Permit fees are associated with <u>issuance</u> of this Discharge Permit. No person shall construe anything in this Discharge Permit as relieving the Permittee of the obligation to pay all permit fees assessed by NMED. A Permittee that ceases discharging or does not commence discharging from the Facility during the term of the Discharge Permit shall pay all permit fees assessed by NMED. NMED shall suspend or terminate an approved Discharge Permit if the Permittee fails to remit an installment payment by its due date.</p> <p>[Subsection F of 20.6.2.3114 NMAC, NMSA 1978, § 74-6-5.K]</p>